

CO₂ Heat Pump Water Heater Tests

What We Know and What We Wish We Knew

Presented by Ken Eklund 2016 ACEEE Hot Water Forum February 22, 2016





WASHINGTON STATE UNIVERSITY

What We Know

The CO₂ Split System HPWH Performs Well

- •As an efficient water heater
- In cold climates
- Meeting an average or larger hot water load
- As a Demand Response provider
- As a Capacity Reducer

HPWH Performance


- Energy per gallon is a great metric to compare water heater performance
- The average energy per gallon over the full field test period was .0475 kWh per gallon
- Electric resistance water heater performance is .22 kWh per gallon or 4 times more energy
- A major field study of US made unitary HPWH averaged .1 kWh per gallon

Field Sites

- 4 homes from the coast to Montana
- Minimum family size of 4—up to 7
- Billing history of at least 3 years with electric resistance water heat
- Avista, ETO, Ravalli Electric, and Tacoma Power found sites

kWh/g for Each Site


Daily Flow and Energy



Savings Potential

- 2.7 people per household (PNW average)
 Use ≈ 45 gal/day
- Split System CO₂ HPWH saves ≈ 0.175 kWh/gal
 - 2,436 kWh/year savings


Cold Weather Performance



Date

HPWH Performance

• kWh per 100 gallons water delivered (inverse Logsdons)



DEMAND RESPONSE

Unitary System



PNNL Lab Home



SPLIT SYSTEM




Extreme Oversupply Mitigation Test

Water Heater Off at 1 pm To Make Room to Absorb Off-Peak Wind Energy

Split System (80 Gallons)

Unitary System (40 Gallons)




Note: the top point on the chart is water temperature – the bottom point is the cooled pipe temperature between draws and not relevant to delivery

DR Value


"A significant amount of [Demand Response] potential, nearly 1,500 megawatts, is available at relatively low cost; less than \$25 per kilowatt of peak capacity per year" 7th Power Plan The controllable power draw of the split system is 1.2 kW. It can also provide 2.6 kW of storage for oversupply mitigation.

Peak Impact

Most Hot Water Demand is at Peak Times




Efficiency Impact of Load Shift



Capacity Reduction

The 7th Pacific NW Regional Power Plan gives a Transmission & Distribution credit of \$12 per MWh



Capacity Value

- Average Annual Load ERWH = 3.2 MWh
- Average Annual Load CO2 HPWH = .8 MWh
- Delta is 2.4 MWh
- @ \$12/MWh = \$28.8 per year in value
- PV at 5% Rate and 20 year life \$360

What We Wish We Knew

Will Utilities Support This Technology?

- Does it get the T&D credit?
- Will it be compared to an electric resistance water heater for cost effectiveness analysis?
 - No electric element
 - No impact on conditioned space
 - Arguably cost-effective if it is compared to ERWH


Benefit to Cost Cost

 CO_2 HPWH with 43 gallon stainless tank = \$2,200 Installation by efficient experts 800 Parts (wholesale) 200 Markup 600 **Total Gross Cost** 3,800 Credit for no ERWH (as per NWPCC) 800 = \$3,000 Net Cost

Benefit to Cost Benefit & Ratio

Annual Savings = 2,436 @ \$.10/kWh = \$244 T & D Value = 2.4 MWh x \$12 29 = \$272 **Total Benefit** = 5% **Discount Rate** Life = 20 yrs Simple Payback 12 yrs = = \$3,395 **PV** Savings **Benefit to Cost Ratio** 1.13 =

NEBs



	GWP	ODP
R-11	7020	1
R-12	4750	1
R-22	1810	0.055
R-134a	1430	0
R-410a	2088	0
CO2 (R-744)	1	0

• Source: <u>http://www.epa.gov/ozone/snap/subsgwps.html</u>

CONCLUSION

- The split system can handle water heating to minus 20 degrees F
- Is 4x as efficient as electric resistance water heating and uses about half current HPWH energy
- Has strong DR capability and high capacity value
- 40 gallon unit can produce 135 gallon per day
- Impact of refrigerant on the climate is minimal

Thanks

To Adria Banks, WSU lead analyst

To Ben Larson, Jonathan Heller, Nick Kvaltine and Colin Grist, Ecotope

To Melinda Spencer, WSU technical editor

To Bruce Carter, Fred Gordon, Rem Husted, Tom Lienhart, & Jim Maunder—utility partner reps

To PNNL's Graham Parker, Joe Petersen & Sarah Widder & Greg Sullivan, Efficiency Solutions

- To Mark Jerome, CLEAResult, lead installer
- To David Hales, WSU lead monitoring installer
- To Janice Peterson, BPA project manager
- To Dave Kresta & Charlie Stephens, NEEA
- To Maho Ito, John Miles, & Charles Yao, Sanden International

To the Regional Advanced HPWH Advisory Task Force

Contact Information

 Ken Eklund, Building Science & Standards Lead Washington State University Energy Program eklundk@energy.wsu.edu
Project Principle Investigator and Manager



Washington State University Energy Program

DISCUSSION