



*the Energy to Lead*

# Field Evaluation of Pre-Commercial Residential Gas Heat Pump Water Heaters

---

Paul Glanville

ACEEE Hot Water Forum

Monday, February 22<sup>nd</sup>, 2016

Portland, OR

# Gas Heat Pump Water Heater – Why?

**Motivation:** Despite low natural gas prices, GHPWH has potential to leapfrog

> Energy/Operating Cost Savings, Fewer Infrastructure Needs, Recent Regulatory Drivers


## Baseline:

~90% of Gas WHs sold.  
At risk with advancing efficiency, combustion safety requirements



## Mid-Efficiency:

UEF approx. 0.67 – 0.72, 50-100% greater equipment costs, simple paybacks beyond life of product.



## Condensing Storage:

UEF approx. 0.74 – 0.82, ~ 20% therm savings with 4-5X equipment cost and retrofit installation costs of \$1000 or more.



## Tankless and Hybrids:

UEF approx. 0.82 – 0.95, ~ 33% therm savings with 2-3X equipment cost and similar infrastructure req's as condensing storage.



## Gas Heat Pump:

UEF approx. 1.3, > 50% therm savings with comparable installed cost to tankless.



Technology Leapfrog through Direct Retrofit

# Gas Heat Pump Water Heater – What?

**GHPWH System Specifications:** Direct-fired NH<sub>3</sub>-H<sub>2</sub>O single-effect absorption cycle integrated with storage tank and heat recovery. Intended as fully retrofittable with most common gas storage water heating, *without infrastructure upgrade*.


	GHPWH	Units/Notes
Technology Developer	Stone Mountain Technologies	OEM support
Heat Pump Output	10,000	Btu/hr
Firing Rate	6,300	Btu/hr
Efficiency	1.3 Energy Factor	Projected
Tank Size	75	Gallons
Backup Heating	Experimenting with backup currently	
Emissions (projected)	10 ng NO <sub>x</sub> /J	Based upon GTI laboratory testing
Commercial Introduction	2017	Projected
Installation	Indoors or semi-conditioned space (garage)	Sealed system has NH <sub>3</sub> charge < 25% allowed by ASHRAE Standard 15
Venting	½" – 1" PVC	
Gas Piping	½"	
Estimated Consumer Cost	<\$1,800	



Information and graphic courtesy of Stone Mountain Technologies, Inc.

# Gas Heat Pump Water Heater – How?

## How it works



- Cooling effect at evaporator is 1/3-1/2 that of electric HPWHs.
- Uses single-effect absorption cycle, more complex cycles were considered by manufacturer but were not cost-effective.
- Features discussed likely to apply to GHPWH product category.


# Gas Heat Pump Water Heater – Where?

## Pac. NW Demonstration (WA/OR/ID)

Four GHPWHs are operating in major NW cities, focusing on seasonal performance, heating system interaction, end user satisfaction, and contractor education.

## Initial Controlled Demonstration (TN)

Two GHPWHs installed near manufacturer, at homes of employee and employee of local utility. Focus on refining system controls and assessing reliability.



Map reference: Baechler, M. et al. "Guide to Determining Climate Regions by County", PNNL-17211, 2010.

# Gas Heat Pump Water Heater – Where?

## Four “3<sup>rd</sup> Gen.” installations focus of this study

- > Three of four installed in semi-conditioned garages, Seattle-area unit installed in conditioned basement.
- > Units installed in parallel to baseline gas water heaters to switch over during periods of prototype servicing.
- > Monitoring period over 9 months, beginning in January 2015.

Boise, ID



Spokane, WA



Portland, OR




Seattle, WA



# Pilot Project Overview - Sites

## Baseline Site Characteristics and Summary:

Compared to typical Pac. NW homes, GHPWH sites have higher than average occupancy (> 2.5) and hot water usage.




Existing WH	Seattle	Spokane	Portland	Boise
Tank Size (Gal.)	40	34	50	40
Firing Rate (Btu/hr)	36,000	100,000	40,000	40,000
Age	14+ Years	18 Years	0 years	13 years
Rated / Avg. Delivered EF/TE	0.59 / 0.56	96% / 0.91	0.62 / 0.47	0.59 / 0.45
Average Inlet T (°F)	53.3	61.2	54.8	58.7
Average Outlet T (°F)	123.8	122.8	115.2	138.0

EHPWH Validation: Heat Pump Water Heater Model Validation Study, Prepared by Ecotope for NEEA, Report #E15-306 (2015)

# Pilot Project Overview - Measurements

## Measurement Scheme (Continuous)



Monitoring Phase	Continuous Measurement
Baseline & GHPWH	<ul style="list-style-type: none"> <li>Indoor T &amp; RH</li> <li>NG Flow</li> <li>Water Flow</li> <li>Power Draw (total)</li> <li>Water inlet/outlet temperatures</li> </ul>
GHPWH Only	<ul style="list-style-type: none"> <li>Gas valve on/off</li> <li>Storage tank thermostat temperature</li> </ul> <p><u>HP Temperatures</u></p> <ul style="list-style-type: none"> <li>Evap in/out</li> <li>Hyd. Loop Rtn/Sup.</li> <li>Desorber shell</li> <li>Flue gas exiting temperature</li> </ul>




# Pilot Project Overview – Metrics

## Efficiency Metrics

- > **Heat Pump COP** – Efficiency of absorption heat pump based only on heat from combustion.
- > **System COP** – Overall efficiency of GHPWH, based on gas/electricity inputs (incl. backup heating).
- > **Delivered Energy Factor** – Transient output/input efficiency metric (akin to rating UEF), includes tank heat loss and mixing effects.

$$COP_{HP} \geq COP_{SYS} \geq DEF$$



$$\dot{Q}_{HP} = 60 \cdot \dot{V}_{hyd} C_P \rho (T_{sup} - T_{rtn})$$

$$COP_{HP} = \dot{Q}_{HP} / (\eta_{TH,DES} \dot{Q}_{NG})$$

$$COP_{SYS} = \frac{(\dot{Q}_{HP} + (\dot{Q}_{NG} - \dot{Q}_{HP,DES}) - \dot{Q}_{FG,out})}{\dot{Q}_{NG} + \dot{Q}_{Elec}}$$


$$Input = m \cdot Output + b;$$

$$\frac{Output}{Input} = DEF = \left( m + \frac{b}{Output} \right)^{-1}$$

# GHPWH Performance and Reliability

## Heat Pump Performance

- >  $COP_{HP}$  at lab test targets (1.4-1.8), near theoretical limits.
- > Generally, low COPs from EEV
- > With reliable heat recovery, steady power consumption (~150W), and minimal backup heating  $COP_{SYS}/COP_{HP}$  has correlation coeff. of 0.83.
- > For all cycles:
  - > 75%  $COP_{HP} > 1.4$
  - > 45%  $COP_{HP} > 1.6$
  - > 68%  $COP_{SYS} > 1.3$
  - > 42%  $COP_{SYS} > 1.4$



# GHPWH Performance and Reliability


## COP less affected by ambient

- > Known from prior lab testing, GHPWH efficiency is affected more by storage tank temperature than ambient air.
  - > Over one cycle, COP and heat pump output drop as tank warms
  - > Over range of ambient air temperatures observed, COP nearly flat for GHPWHs

## Evaporator cooling effect is small

- > Function of cycle COP, higher efficiency – greater cooling effect (same as EHPWHs).
- > Observed range from 2,500-4,000 Btu/hr

## Portland GHPWH Recovery 2/2




# GHPWH Performance and Reliability

## Reliability: Electronic Expansion Valve


- > With reliable EEV performance, GHPWH can take advantage of colder tank temperatures during beginning of on-cycle, increasing efficiency/output capacity.
- > Component affected all sites, off-design operation, required servicing



Seattle – EEV Working Well



Seattle – EEV Not Working Well




# GHPWH Predicted Savings

## Therm Savings of 50% or more


- > Charting daily input/output creates linear “input/output” relationship, **for gas input only.**
- > In comparison to baseline, all sites showed greater than 50% savings except for Spokane with Polaris.
- > Sites had large range of daily hot water usage, average from 41 – 96 gal/day.

	Output	Low Usage (Seattle)	High Usage (Portland)
Daily DHW Draw (gal)		41	96
Baseline	64 gal/day	0.59	0.48
	84 gal/day	0.60	0.50
GHPWH	64 gal/day	1.21	1.15
	84 gal/day	1.25	1.18



# GHPWH Predicted Savings



Delivered Efficiency by Site: Solid = GHPWH, Dashed = Baseline



# GHPWH Predicted Savings

## Projected GHPWH Economics

For DOE “High Usage” category, GHPWHs have projected  $1.2 < DEF < 1.3$ ,  $> 50\%$  savings versus baseline (except Spokane), can be competitive for moderate/high usage homes despite low NG prices. With new min. eff. guidelines ***GHPWH leapfrogs condensing storage.***




**Utility Costs:** Assumes OR averages of 11.72 ¢/kWh, \$1.11/therm with 1.9% and 1.2% utility escalation rates per EIA 2015 Annual Energy Outlook through 2027.

**Conventional Gas Water Heater Data from:** Kosar, D. et al. "Residential Water Heating Program - Facilitating the Market Transformation to Higher Efficiency Gas-Fired Water Heating - Final Project Report". CEC Contract CEC-500-2013-060. (2013) Link: <http://www.energy.ca.gov/publications/displayOneReport.php?pubNum=CEC-500-2013-060>

# End User/Contractor Feedback

## Feedback on Hot Water Capacity

- For three sites, each with 4+ occupants, hosts noted periods of low capacity. Upon inspection, high loading events did result  $T_{\text{outlet}} < 105$  F. Case below shows high loading managed with cycling and backup heat.







# End User/Contractor Feedback

## End user nuisances minimal

- > No complaints drafts or excessive cooling. Non-garage installation noted noise levels. Units noise observed to be near Tier I.

	Seattle	Spokane	Portland	Boise
Noise, dB (Average per NEEA Spec.)	67.5	64.8	66.4	64.6

## Installations straightforward, though unit size noted as challenge

- > Venting through external wall using new penetration (B, P, Se) or existing vent (Sp).
- > Condensate drained to accessible drain (B) or with other condensing equipment (P, Se, Sp). Gas line access OK.

Photos of Boise site highlight:

- > Gas/Water connections
- > 3/4" PVC flue pipe
- > Condensate lines



# Questions & Answers



**Gas Technology Institute**  
1700 S Mount Prospect Rd,  
Des Plaines, IL 60018, USA  
[www.gastechnology.org](http://www.gastechnology.org)

   @gastechnology



<http://www.stonemountaitechnologies.com/>