

# Ground-Source Integrated Heat Pump System – field measured WH performance

**2016 ACEEE  
Hot Water Forum**

Shawn Hern – ClimateMaster, Inc.  
Van Baxter, Jeff Munk, and Tony Gehl – Oak Ridge  
National Laboratory

Portland, OR  
February, 22-23, 2016


ORNL is managed by UT-Battelle  
for the US Department of Energy



# Contents

1. GS-IHP system description
2. Field test site and monitoring approach descriptions
3. Test results
4. Concluding observations

# GS-IHP System description



Integral hot water storage tank

Water source heat pump (WSHP) unit with variable speed compressor, blower, and pumps;  
System controller

Knoxville, TN  
Day care center  
Test system installation

# GS-IHP System description

- Variable speed (VS) WSHP utilizing a unique refrigerant circuit to reliably allow 4 modes of operation:
  - Space heating (SH)
  - Space cooling (SC)
  - Space cooling + domestic water heating (SC+WH)
  - Dedicated domestic water heating (WH)
- VS compressor allows 1) constant WH output regardless of ground temp. and 2) a “boost” WH capacity mode when the SH demand is high to decrease the tank recovery time.
  - WH has priority unless space temp. falls below min. limit in winter

# GS-IHP System description


- The packaged system includes a customized version of a commercially available water storage tank and integral system control board
  - electric elements used for backup or emergency WH
- Communications between controller, WSHP, and storage tank
  - monitors set points, space, tank water, and loop temperatures, and operation modes for optimal system and comfort control
    - lower tank temperature controls heat pump WH operation
    - upper tank temperature controls upper element backup operation
- Large 1-1/4” hot water injection port below lower element reduces tank mixing to acceptable levels.



# GS-IHP Schematic: SC+WH mode

| Circuit Legend |                            |
|----------------|----------------------------|
|                | High Pressure Hot Gas      |
|                | High Pressure Hot Liquid   |
|                | Low Pressure Cool Liquid   |
|                | Low Pressure Cool Gas      |
|                | Unused Refrigerant Circuit |
|                | Water (DHW & Loop)         |


## Trilogy Variable GSHP Cooling + DHW




# GS-IHP Schematic: WH only mode

| Circuit Legend |                            |
|----------------|----------------------------|
|                | High Pressure Hot Gas      |
|                | High Pressure Hot Liquid   |
|                | Low Pressure Cool Liquid   |
|                | Low Pressure Cool Gas      |
|                | Unused Refrigerant Circuit |
|                | Water (DHW & Loop)         |

## Trilogy Variable GSHP DHW



# Field Test Sites



Knoxville, TN  
Day care center  
Kitchen

Oklahoma City, OK  
Homeless shelter  
dormitory





# Field Test Sites




Knoxville, TN  
Day care center  
Kitchen  
Aerial view  
(Photo courtesy  
Google Maps)

Kitchen area layout



# Field Test Sites

Knoxville, TN  
Day care center  
Test system installation






# Field Test Sites





Oklahoma City, OK  
Homeless shelter dormitory  
Two GS-IHP units each serving 10  
dormitory units of 250 ft<sup>2</sup> each  
Two other non-integrated GSHPs  
serving building common areas and  
offices

GHX – ten vertical boreholes,  
each 500 ft. deep and 25 ft.  
apart



# Field Test Monitoring Approach



Data logger @ Knoxville site



WH meters @ Knoxville site

## Sensor locations

- Monitoring start August 2015 at Knoxville
- Monitoring start late January 2016 at OKCity



# Field Test Data Analysis Approach

Space cooling delivered (SC Mode)

$$Q_{SC} = V_{GroundLoop} \rho_{GroundLoop} c_{GroundLoop} (LWT - EWT) - W_{IHP}$$

Space cooling delivered (SC +WH Mode)

$$Q_{SC} = Q_{WH,IHP} - W_{IHP}$$

Space heating delivered

$$Q_{SH} = V_{GroundLoop} \rho_{GroundLoop} c_{GroundLoop} (EWT - LWT) + W_{IHP}$$

Water heating delivered by IHP

$$Q_{WH,IHP} = V_{DHWLoop} \rho_{DHWLoop} c_{DHWLoop} (LDHWT - EDHWT)$$

Water heating delivered to building

$$Q_{WH} = V_{Hot} \rho_{Hot} c_{Hot} (T_{Hot}^1 - T_{Cold})$$

<sup>1</sup> Due to the numerous small volume hot water draws and the response time of the hot water temperature sensor,  $T_{Hot}$  was taken to be the tank temperature measured at the upper element.

NOTE --

Simulated performance of baseline RTU/heat pump + electric storage WH system operating under same delivered loads and indoor/outdoor conditions as GS-IHP for energy savings estimation


# GS-IHP Field Test Unit vs. Baseline performance ratings

| Parameters               | GS-IHP   | Baseline RTU/WH  |
|--------------------------|--|--|
| Cooling capacity (Btu/h) | 18,000 (min speed, 68F EWT) <sup>a</sup><br>48,000 (max speed, 77F EWT) <sup>a</sup> | 48,000 @ 95F <sup>b</sup>                              |
| Cooling EER              | 45.1 (min speed, 68F EWT) <sup>a</sup><br>21.6 (max speed, 77F EWT) <sup>a</sup>     | 11.4 @ 95F <sup>b</sup>                                |
| Cooling SEER             | na   | 13.0 <sup>b</sup>                                      |
| Heating capacity (Btu/h) | 24,000 (min speed, 41F EWT) <sup>a</sup><br>60,000 (max speed, 32F EWT) <sup>a</sup> | 45,000 @ 47F <sup>b</sup><br>28,000 @ 17F <sup>b</sup> |
| Heating COP              | 5.1 (min speed, 41F EWT) <sup>a</sup><br>3.3 (max speed, 32F EWT) <sup>a</sup>       | 3.05 @ 47F <sup>b</sup><br>2.26 @ 17F <sup>b</sup>     |
| WH capacity (kW)         | ~8.2-11.7 for 110F HW entering &<br>35-80F EWT                                       | 4.5  |
| WH COP (or EF)           | ~2.5-5.0   | 1.00 (0.94 EF)   |
| SC+WH combined EER       | Up to 30 (min speed)<br>Up to 19 (max speed)<br>110 F entering HW                    | na   |

<sup>a</sup>Ratings per ANSI/AHRI/ASHRAE/ISO 13256-1; water source heat pumps;  
EWT → entering ground HX fluid temperature

<sup>b</sup>Ratings per ANSI/AHRI 210/240; air source heat pumps


# Kitchen WH demand profile



- Full season WH demand profile
  - operating hours: ~7-5, 5 days/week

# GS-IHP system energy and HW use for week of 8/30-9/5/2015

Hourly averages (temperatures, °F) or totals (gallons, Wh/100)





# GS-IHP Field Test Unit vs. Baseline

## August-December field performance, Knoxville

| Parameters  | GS-IHP<br>(measured) | Baseline RTU/WH<br>(estimated) |
|---|----------------------|--------------------------------|
| Total space cooling (SC) delivered, kWh                   | 5943                 | 5943                           |
| SC energy use, kWh<br>(GS-IHP savings vs. baseline)       | 766<br>(44.6%)       | 1382                           |
| Average SC COP  | 7.75 <sup>a</sup>    | 4.30                           |
| Total space heating delivered, kWh                        | 0.0                  | 0.0                            |
| Water heating (WH)  |                      |                                |
| WH from heat pump to tank, kWh                            | 863                  | --                             |
| WH del. to kitchen, kWh (gal.)                            | 703 (~6700)          | 703 (~6700)                    |
| GS-IHP tank backup, kWh                                   | 0.8                  | --                             |
| Total WH energy use, kWh<br>(GS-IHP savings vs. baseline) | 197<br>(73.7%)       | 748                            |
| Average WH COP or EF                                      | 3.57 <sup>b</sup>    | 0.94                           |
| Total system energy use (savings %)                       | 1011 (53.6%)         | 2178 (--)                      |
| Carbon eq. emissions (MT)                                 | 0.7                  | 1.5                            |

<sup>a</sup>Combined value for SC only and SC+WH modes

<sup>b</sup>Combined value for WH only and SC+WH modes; based on WH delivered to kitchen

# GS-IHP Field Test Unit vs. Baseline

## August-December monthly avg. hourly peak kW

| Month                                  | GS-IHP<br>(% reduction<br>for GS-IHP) | Baseline<br>RTU/HP + WH<br>(estimated) |
|--|---------------------------------------|--|
| August 18-31                           | 1.705 (58.9%)                         | 4.153                                  |
| September 1-30                         | 2.923 (32.9%)                         | 4.357                                  |
| October 1-31                           | 1.642 (57.4%)                         | 3.851                                  |
| November 1-30                          | 1.888 (59.0%)                         | 4.609                                  |
| December 1-14                          | 1.531 (57.5%)                         | 3.606                                  |
| Total period<br>maximum peak<br>demand | 2.923                                 | 4.609                                  |

Peaks generally occurred in early afternoon  
Noon-1pm or 1-2pm

# GS-IHP Field Test Unit vs. Baseline

## Total energy cost savings for August 18 - December 14 test period (based on local utility rate structure)

|                                  | GS-IHP           | Baseline<br>RTU/HP + WH |
|----------------------------------|------------------|-------------------------|
| Electricity consumption          | \$118            | \$254                   |
| Electricity demand               | \$131            | \$277                   |
| Total costs                      | \$249            | \$531                   |
| Energy cost savings vs. baseline | \$282<br>(53.1%) | --                      |

# Summary

- GS-IHP system demonstrated ~54% energy savings vs. simulated RTU/heat pump + electric storage WH baseline system meeting same loads at the Knoxville test location
- up to ~60% monthly hourly peak kW reduction vs. base RTU/WH
- Energy cost savings of ~53% for GS-IHP
  - More than half from demand cost reduction
- Field demonstration to continue through August 2016 with data from both sites
  - Final report will include cost/payback analysis



# Questions?

**Shawn Hern** – [shern@climatemaster.com](mailto:shern@climatemaster.com)

**WSHP website:**

<http://www.climatemaster.com/residential/climatemaster-trilogy-45-mode-series-heat-pump/>

**Van Baxter** – [vdb@ornl.gov](mailto:vdb@ornl.gov)