

*the Energy to Lead*

# High Efficiency, Low Emissions Combustion for Commercial Hot Water Boilers

---

*ACEEE Hot Water Forum  
Portland, OR*

David Cygan and Sandeep Alavandi  
Energy Delivery and Utilization

March 21, 2018

# Acknowledgement

---

This work effort was supported by the California Energy Commission, PIR-14-004 and Southern California Gas Company

# Outline

---

- > Technology Overview
- > Burner Development
- > Tests on GTI's Boiler Simulator
- > Computational Modeling
- > Tests on Commercial Scale Boiler at GTI
- > Tests at a Commercial Laundry Facility in California
- > Conclusions

# Gas Technology Institute (GTI) Overview

- > Not-for-profit (501c3) R&D organization with 75 year history
- > Facilities
  - 18 acre campus near Chicago
  - 200,000 ft<sup>2</sup> with 28 specialized labs
  - Other sites in California, D.C., Texas, Pittsburgh
- > Staff
  - 300+ engineers, scientists covering a variety of energy fields



Source: GTI

**Industrial and Power Lab**



Source: GTI




Source: GTI


**Residential & Commercial Lab**

# Dynamic Staged Entrainment (DSE) Burner

- > Designed specifically for commercial heating applications
- > Incorporates dynamic flow geometry for induced entrainment of cooled products of combustion
- > Allows combustion staging




Source: GTI



Source: GTI

# Reducing Excess Air Improves Boiler Efficiency



Source: GTI


# Burner Development Project

---

- > GTI designed, developed, tested, commissioned and monitored operation for over a year an ultra-low emissions natural gas boiler system for hot water and steam applications
- > Boiler/burner rated at 5.25 MMBtu/hr
  - Capable of achieving <9 ppmv NO<sub>x</sub>
  - CO emissions <20 ppmv
  - Turndown of >4:1
- > Successful operation for 10,000+ hours
- > Advanced and improved controls and monitoring
- > Partners – GTI; Power Flame, Inc.; Mission Linen Supply; Tetra Tech, Inc. and California Boiler

# Testing on Boiler Simulator at GTI

- > Testing performed at GTI on a boiler simulator capable of full firing rate
- > Measurements included:
  - Emissions
  - Turndown
  - Efficiency
  - Operating characteristics
  - Pressure drop
- > Design improvements performed with multiple design iterations
- > Testing also provided data for developing and evaluating computational model





Source: GTI




# Computation Model Development and Validation

Actual Mixing – Air and natural gas introduced separately as in commercial systems



Source: GTI




Source: GTI

A section of the design was modeled

Model showed good agreement with experimental NOx and pressure drop measurements for well mixed combustion

# Computational NOx Prediction for Design Changes

- > NOx emissions were evaluated for design changes to the burner
- > Designs showing lowest NOx emissions were experimentally evaluated



Source: GTI

# Selected Laboratory Test Results

Test performance data for DSE system					
Load [%]	25	52	68	84	100
Excess Air [%]	25	25	24	28	33
CO [ppmv]	60	5	7	3	2
NOx [ppmv]	7.4	7.0	8.5	8.6	7.7

Source: GTI

# Testing on Commercial Boiler at GTI

- > A commercial scale boiler with controls, gas train and flow valves was acquired and installed at GTI
- > The nominal 5.25 MMBtu/hr DSE burner with its own controls was installed on the boiler
- > Performance testing was conducted to compare and evaluate boiler/burner performance with boiler simulator results



Source: GTI, all

# Boiler/Burner Controls

Boiler controls and boiler were operated independently of GTI controls to allow maximum flexibility during performance testing



Source: GTI




Source: GTI

# Boiler Tuning


Fuel/Air ratio and trim controls were employed to tune boiler/burner operation

Fuel/Air Control Output



Source: GTI


Fuel/Air Trim Control Output



Source: GTI

# NOx Emissions

Results were consistent with those from the boiler simulator, achieving <5 ppmv NOx at full fire



Source: GTI

# Shipping to Host Facility

- > Complete boiler/burner system with controls was loaded on a flat bed truck as one unit and shipped to the host facility in California



Source: GTI



# Installation and Commissioning at the Laundry Facility

- > Building and air quality permits were acquired
- > Boiler with DSE burner was unloaded and installed in the boiler room
- > All electrical and mechanical connections were completed and the system was commissioned



Source: GTI, all

# On-Site Boiler Tuning

Boiler/burner was tuned to recommended operating specifications using feed water, air/fuel ratio and trim controls

Boiler/Burner at the Laundry Facility




Source: GTI

Natural Gas Roots Meter



Source: GTI

Boiler Performance Monitor Display




Source: GTI

# Independent Third Party Testing

- > Source testing was carried out by Almega Environmental for process parameters, stack gas parameters and NO<sub>x</sub>, CO and VOC emissions
  - Firing rate – 4.87 MMBtu/hr (92.7% of rated capacity)
  - Stack gas temperature – 413°F
  - O<sub>2</sub> – 5.1%
  - CO<sub>2</sub> – 9.2%
  - NO<sub>x</sub> – 8.6 ppmv
  - CO – <10 ppmv
  - VOC – <0.1 ppmv


# On Site Continuous Operation – Fuel Flow Cycling

- > Completed 10,000+ hours on-site field operation
- > Achieved stable cyclic operation with advanced controls



Source: GTI

# On Site Continuous Operation – Stack Temperature



Source: GTI

# Conclusions

---

- > Based on tests carried out on a commercial scale burner at GTI and in the field, it is concluded that:
  - GTI's DSE combustion concept can be employed in commercial scale boilers with potential to provide sub 9 ppmv NO<sub>x</sub>, with low CO, high turndown ratio and improved system thermal efficiency
  - A nominal 5.25 MMBtu/hr DSE burner has logged over 10,000 hours of operation in laboratory and field settings, demonstrating its commercial viability

---

# Questions ?