

Maximum Efficiency Heat Pump Water Heater Based on Low-GWP Hydrofluoroolefin Refrigerants

Kashif Nawaz
Bo Shen
Ahmed Elatar
Van Baxter
Omar Abdelaziz

ACEEE 2019 Hot Water Forum, Nashville

Content

- Background
- Potential alternative refrigerants
- Model development and results
- Experimental validation
- Conclusions


Next Generation Refrigerants

Refrigerant	GWP ₁₀₀
CO ₂	1
R-22	1760
R-134a	1300
R-410A	1924

- Hydrofluoroolefins (HFOs)

- Fluorinated propene isomers
 - R-1234yf (CF3CF=CH2)
 - R-1234ze (CF3CH=CHF)
- GWP < 4
- Mildly flammable

Chemical compounds



Away from Chlorine (ODP) and Fluorine (GWP) inevitably leads to flammability


Goals

Identify appropriate substitute for R-134a as HFCs will phase out:


- **Evaluate the potential of HFOs to replace the conventional working fluid (R134a) for a residential hybrid heat pump water heater.**
 - Low GWP, no direct environmental impact
 - No major modification of existing system is desired.
 - Performance FHR and UEF should be comparable.

Alternative Refrigerants


Refrigerant	Composition (mass %)	at 45 F					at 155 F	
		T_c (K)	P_c (Mpa)	P_{sat} (Mpa)	h_{fg} (KJ/kg)	P_{vap} (kg/m ³)	Vol. Cap (KJ/m ³)	P_{sat} (Mpa)
R134a	Pure	374.21	4.06	0.3774	193.17	18.66	3604.55	2.04
R1234yf	Pure	367.85	3.38	0.4006	158.52	22.253	3527.55	1.9725
R1234ze	Pure	382.51	3.64	0.2803	179.49	15.004	2693.07	1.551




HFO-1243zf




HCFO-1224yd




HCFO-1233zd




HFO-1216




HFO-1336mzz(Z)



HFO-1234yf




HFO-1234ze(E)



HFO-1234ze(Z)


Model development- ORNL HPDM



B. Shen, K. Nawaz, A. Elatar, V. Baxter, "Development and Validation of Quasi-Steady-State Heat Pump Water Heater Model Having Stratified Water Tank and Wrapped-Tank Condenser" International Journal of Refrigeration, 2018, 87,78-90.

Design Parameters

- 46-gallon water tank
- Heat pump T-stat at the top: on at 115 °F, off at 125 °F.
- Electric element at the top: on at 110°F, off at 125 °F.
- Two different evaporator sizes and evaporator flow rate
- Two different heat loss factors from tank
- Two different condenser coil wrap patterns
- Two different condenser tube sizes




Condenser wrap configurations (a) counter flow (b) parallel-counter flow

Design Parameters

Case number	Wrap pattern	Evaporator size*	Tank insulation effectiveness (%)	Condenser tube size (inches)
1	Parallel-counter	1 Evap	90	0.31
2	Parallel-counter	1 Evap	90	0.50
3	Parallel-counter	2 Evap	90	0.31
4	Parallel-counter	2 Evap	90	0.50
5	Parallel-counter	1 Evap	95	0.31
6	Parallel-counter	1 Evap	95	0.50
7	Parallel-counter	2 Evap	95	0.31
8	Parallel-counter	2 Evap	95	0.50
9	Counter	1 Evap	90	0.31
10	Counter	1 Evap	90	0.50
11	Counter	2 Evap	90	0.31
12	Counter	2 Evap	90	0.50
13	Counter	1 Evap	95	0.31
14	Counter	1 Evap	95	0.50
15	Counter	2 Evap	95	0.31
16	Counter	2 Evap	95	0.50

First Hour Rating (FHR)




Performance Evaluation Criteria

FHR greater or equal to (gals)	FHR less than (gals)	Draw pattern for 24-hr UEF
0	20	Point of use
20	55	Low usage
55	80	Medium usage
80	Max	High usage


Draw Number	Time During Test (hh:mm)	Volume (gals/L)	Flow Rate (GPM/LPM)
1	00:00	15.0 (56.8)	1.7 (6.5)
2	00:30	2.0 (7.6)	1 (3.8)
3	01:40	9.0 (34.1)	1.7 (6.5)
4	10:30	9.0 (34.1)	1.7 (6.5)
5	11:30	5.0 (18.9)	1.7 (6.5)
6	12:00	1.0 (3.8)	1 (3.8)
7	12:45	1.0 (3.8)	1 (3.8)
8	12:50	1.0 (3.8)	1 (3.8)
9	16:00	1.0 (3.8)	1 (3.8)
10	16:15	2.0 (7.6)	1 (3.8)
11	16:45	2.0 (7.6)	1.7 (6.5)
12	17:00	7.0 (26.5)	1.7 (6.5)
Total Volume Drawn Per Day: 55 gallons (208 L)			

Medium usage draw pattern


Unified Energy Factor




Coefficient of Performance




Heat Pump Run Time




Total Charge in the Condenser and Evaporator




Max Compressor Discharge Temperature



Condenser wrap configuration- Impact on stratification




Experimental Validation





Old study: Baxter et al., 2016

Experimental Validation- Charge Optimization



Experimental Validation




Experimental Validation

Parameter	R134a	R1234yf
Optimum refrigerant charge	2.3	2.2
First Hour Rating (FHR)	66	68
Unified Energy Factor	3.44	3.40

*including 0.70 lbs of charge in flow meter line

Conclusions

- R1234yf is a feasible working fluid for residential HPWHs with comparable performance as R134a.
- R1234ze (E) has reduced capacity- System modification is required for comparable capacity.
- The experimental results validate the simulation findings.



Acknowledgements

DOE Building Technologies Office, Emerging Technologies –
Antonio Bouza (Program Manager)

A O Smith Manufacturing –
Steve Memory (Director, Thermal and Materials)
Jiammin Yin (Lead Designer)

THANK YOU

Kashif Nawaz
nawazk@ornl.gov

